




DET NORSKE VERITAS

EC-TYPE EXAMINATION CERTIFICATE

- [2] **EQUIPMENT OR PROTECTIVE SYSTEM INTENDED FOR USE IN POTENTIALLY EXPLOSIVE ATMOSPHERES DIRECTIVE 94/9/EC**
- [3] EC-Type Examination Certificate Number: **DNV 11 ATEX 99645X**
- [4] Equipment or Protective System: **Ex d motors**
- [5] Applicant – Manufacturer or Authorized representative: **HIGEN MOTOR CO., LTD.**
- [6] Address: **74-5, SEONGSAN-DONG, CHANGWON-SI
KOREA**
- [7] This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- [8] DNV, notified body number 0575 in accordance with Article 9 of Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- The examination and test results are recorded in confidential reports listed in section 14.
- [9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
EN 60079-0: 2009 and EN 60079-1: 2007
- [10] If the sign “X” is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- [11] This EC-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protected system. If applicable, further requirements of this Directive apply to the manufacturer and supply of this equipment or protective system.
- [12] The marking of the equipment or protective system shall include the following:

 II 2 G Ex d IIC/IIB T5/T6 Gb -20°C ≤ Ta ≤ +50°C

Høvik, 2011-10-14
for Det Norske Veritas AS


Marianne Spæren
Certification Manager



Notice: This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.

The digitally signed and electronically distributed document is the original and valid certificate. Ref.: www.dnv.com/digitalsignatures

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 300.000. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.





[13]

Schedule

[14] EC-TYPE EXAMINATION CERTIFICATE No.: DNV 11 ATEX 99645X

Certificate History

Revision	Description	Report no.	Issue date
-	Original certificate	2011-3210	2011-10-14

[15] **Description of Equipment or Protective System**

Three-phase one speed ac squirrel cage induction motor intended to be used with a variable speed drive. The temperature limitation is based on the torque limiting capacity of the drive and temperature sensing elements in the windings. Cooling by an external blower. The windings are of class F insulation.

Duty Types : TEFC(S1 and S3~S9) , TENV(S2 30min.) , TEAO(S1)

TEFC : External fan is attached to the shaft end for the circulation of air around the enclosure.

TENV : Cooling without using a fan. (Duty Type : S2 30min.)

TEAO : Cooling air is blown over the totally enclosed motor surface by an separately fan.

Motors without fan can deliver same output power provided installation is according to IC418.

(Direct driven fan motors without cooling fan on the motor.)

The 2 pole to 8 poles protection types and motors rating

Type Identification	Ex code	IP	Operation mode and T classification	Electrical Data	Rpm
DB3D 132S	Ex d IIB	56	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 1,8 -11kW	750 - 3600
DB3D 132M	Ex d IIB	56	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 1,8 -11kW	750 - 3600
DC3D 132S	Ex d IIC	66	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 1,8 -11kW	750 - 3600
DC3D 132M	Ex d IIC	66	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 1,8 -11kW	750 - 3600

Nomenclature

D	C	3	D	132	S	04	B30	FC	380	/	60
①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩		⑩

1st, D: Flameproof

2nd, B:IIB, C:IIC

3rd, three phase 1 speed

4th, terminal box protection type, D:Ex d

5th, frame number

6th, core length, S or M

7th, number of poles, 02: 2poles, 04: 4poles, 06: 6poles, 08:8poles

8th, mounting, B3, B5, B35, V1, V3, V5, V6

9th, ventilation, FC:TEFC, NV:TENV, AO:TEAO

10th, voltage & frequency

[16] Project No.: PRJC-224371-2010-PRC-KOR

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 300.000. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.





EC-TYPE EXAMINATION CERTIFICATE No.: DNV 11 ATEX 99645X

Descriptive Documents

Number	Title	Rev.	Date
4682EHCL01	Motor Assembly 132S/M IIB	1	2011.07.25
4682EHCL02	Motor Assembly 132S/M IIC	1	2011.07.25
2242EL0001	Parts list 132S/M IIB	0	2011.06.10
2242EL0002	Parts list 132S/M IIC	0	2011.06.10
3844EZ0001	Labeling 132S/M IIB	0	2011.06.17
3844EZ0002	Labeling 132S/M IIC	0	2011.06.17
3210E2L001	Frame 132S Horizontal	1	2011.09.08
3210E2L002	Frame 132M Horizontal	1	2011.09.08
3210E2L003	Frame 132S Vertical	1	2011.09.08
3210E2L004	Frame 132M Vertical	1	2011.09.08
4810E2L001	Bracket 132Fr. Front	0	2010.12.30
4810E2L002	Bracket 132Fr. Rear	0	2010.12.30
4810E2L003	Bracket 132Fr. Flange	0	2010.12.30
4370E3L001	Shaft	0	2010.10.26
4370E3L002	Shaft	0	2010.10.26
4830E3N001	Bushing	0	2010.12.01
3040E3N001	Terminal Base	1	2011.07.25
3550E3N001	Terminal Cover	0	2010.10.18
5900KK3019	Fan 2Pole	0	1999.03.02
5900KK3021	Fan 4...8Pole	0	1999.02.01
3550KK3879	Fan Cover Horizontal	0	2002.08.20
3550KK3880	Fan Cover Vertical	0	2004.11.15

Routine test

Each enclosure must be routine pressure tested with for 60 seconds according to clause 16 of EN/IEC 60079-1.

ITEM	Overpressure kPa
DB3D frame	902
DB3D terminal box	1127
DC3D frame	1190
DC3D terminal box	1390

[17] Special Conditions for Safe Use

Repairs of the flameproof joints must be made in compliance with the structural specifications provided by the manufacturer. Repairs must not be made on the basis of values specified in tables 1 and 2 of EN/IEC 60079-1.

The tensile strength of the fastener elements of each part of the flame proof casing must be at least equal to 1220N/mm².

[18] Essential Health and Safety Requirements

See part 9 of this certificate

END OF CERTIFICATE

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 300.000. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.

