





# DET NORSKE VERITAS

## EC-TYPE EXAMINATION CERTIFICATE

- [2] EQUIPMENT OR PROTECTIVE SYSTEM INTENDED FOR USE IN POTENTIALLY EXPLOSIVE ATMOSPHERES DIRECTIVE 94/9/EC
- [3] EC-Type Examination Certificate Number: **DNV 12 ATEX 08649X**
- [4] Equipment or Protective System: **Ex d motors**
- [5] Applicant – Manufacturer or Authorized representative: **HIGEN MOTOR CO., LTD.**
- [6] Address: **74-5, SEONGSAN-DONG, CHANGWON-SI  
KOREA**
- [7] This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- [8] DNV, notified body number 0575 in accordance with Article 9 of Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- The examination and test results are recorded in confidential reports listed in section 14.
- [9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN 60079-0: 2009 and EN 60079-1: 2007**
- [10] If the sign “X” is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- [11] This EC-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protected system. If applicable, further requirements of this Directive apply to the manufacturer and supply of this equipment or protective system.
- [12] The marking of the equipment or protective system shall include the following:

 II 2 G Ex d IIC/IIB T5/T6 Gb -20°C ≤ Ta ≤ +50°C

Høvik, 2012-05-02  
for Det Norske Veritas AS

  
for Marianne Spæren  
Certification Manager



Notice: This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.

The digitally signed and electronically distributed document is the original and valid certificate. Ref.: [www.dnv.com/digitalsignatures](http://www.dnv.com/digitalsignatures)

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 300 000. In this provision 'Det Norske Veritas' shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.





[13]

## Schedule

[14] EC-TYPE EXAMINATION CERTIFICATE No.: DNV 12 ATEX 08649X

### Certificate History

Revision	Description	Report no.	Issue date
-	Original certificate	2012-9202	2012-05-02

[15] Description of Equipment or Protective System

Three-phase one speed ac squirrel cage induction motor intended to be used with a variable speed drive. The temperature limitation is based on the torque limiting capacity of the drive and temperature sensing elements in the windings. Cooling is an external blower. The windings are of class F insulation.

Duty Types : TEFC(S1 and S3~S9) , TENV(S2 30min.) , TEAO(S1)

TEFC : External fan is attached to the shaft end for the circulation of air around the enclosure.

TENV : Cooling without using a fan. (Duty Type : S2 30min.)

TEAO : Cooling air is blown over the totally enclosed motor surface by an separately fan.

Motors without fan can deliver same output power provided installation is according to IC418.

(Direct driven fan motors without cooling fan on the motor.)

### The 2 pole to 8 poles protection types and motors rating

Type Identification	Ex code	IP	Operation mode and T classification	Electrical Data	Rpm
DB3D 180M	Ex d IIB	56	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 10,6 -31,7kW	750 - 3600
DB3D 180L	Ex d IIB	56	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 13,6 -40,0kW	750 - 3600
DC3D 180M	Ex d IIC	66	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 10,6 -31,71kW	750 - 3600
DC3D 180L	Ex d IIC	66	(S1 - S9)T5 or (S1 - S2)T6	200-690V 50/60Hz 13,6 -40,0kW	750 - 3600

### Nomenclature

D	C	3	D	180	M	04	B30	FC	380	/	60
①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩		⑩

1<sup>st</sup>; D: Flameproof

2<sup>nd</sup>; B:IIB, C:IIC

3<sup>rd</sup>; three phase 1 speed

4<sup>th</sup>; terminal box protection type, D:Ex d

5<sup>th</sup>; frame number

6<sup>th</sup>; core length, L or M

7<sup>th</sup>; number of poles, 02: 2poles, 04: 4poles, 06: 6poles, 08:8poles

8<sup>th</sup>; mounting, B3, B5, B35, V1, V3, V5, V6

9<sup>th</sup>; ventilation, FC:TEFC, NV:TENV, AO:TEAO

10<sup>th</sup>; voltage & frequency

[16] Project No.: PRJC-224371-2010-PRC-KOR

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 300,000. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.



**EC-TYPE EXAMINATION CERTIFICATE No.: DNV 12 ATEX 08649X**

**Descriptive Documents**

Number	Title	Rev.	Date
4682EHCP01	Motor Assembly 180M/L IIB	0	2011.08.19
4682EHCP02	Motor Assembly 180M/L IIC	0	2011.08.19
2242EP0001	Parts list 180M/L IIB	0	2011.08.19
2242EP0002	Parts list 180M/L IIC	0	2011.08.19
3844EZ0011	Labeling 180M/L IIB	0	2011.08.23
3844EZ0012	Labeling 180M/L IIC	0	2011.08.23
3210E2P001	Frame 180M Horizontal	0	2010.12.30
3210E2P002	Frame 180L Horizontal	0	2010.12.30
3210E2P003	Frame 180M Vertical	0	2010.12.30
3210E2P004	Frame 180L Vertical	0	2010.12.30
4810E2P001	Bracket 180Fr. Front	0	2010.12.30
4810E2P002	Bracket 180Fr. Rear	0	2010.12.30
4810E2P003	Bracket 180Fr. Flange	0	2010.12.30
3550E3P001	Bearing cover Front. In	0	2010.08.26
3550E3P002	Bearing cover Front. Out	0	2010.08.26
3550E3P003	Bearing cover Rear. In	0	2010.08.26
3550E3P004	Bearing cover Rear. Out	0	2010.08.26
3040E3P002	Terminal Base	0	2010.08.26
3550E3P005	Terminal Cover	0	2010.09.29
4370E3P001	Shaft 4...8Pole	0	2010.12.28
4370E3P002	Shaft 2Pole	0	2010.12.28
4830E3N001	Bushing	0	2010.12.01
3M95960	Fan 4...8Pole	0	1991.01.18
5900KK3033	Fan 2Pole	0	2004.03.16
2M95417	Fan Cover	0	2008.06.05

**Routine test**

Each enclosure must be routine pressure tested with for 60 seconds according to clause 16 of EN/IEC 60079-1.

ITEM	Overpressure kPa
DB3D frame	1 296
DB3D terminal box	1 089
DC3D frame	1 635
DC3D terminal box	1 286

**[17] Special Conditions for Safe Use**

Repairs of the flameproof joints must be made in compliance with the structural specifications provided by the manufacturer. Repairs must not be made on the basis of values specified in tables 1 and 2 of EN/IEC 60079-1.

The tensile strength of the fastener elements of each part of the flame proof casing must be at least equal to 1220N/mm<sup>2</sup>.

**[18] Essential Health and Safety Requirements**

See part 9 of this certificate

**END OF CERTIFICATE**

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 300.000. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.

