HIDEN			INDUCTION MOTOR DATA SHEET					5.5	kW -	4	Р
MODEL: I08HV1KBS3			CUSTOMER:				REV. I	NO :			
APPLICATION:			PROJECT NAME:					TITY :			
	PERFORMANCE DATA										
FRAME NO.			132S	OUTPUT			5.5				kW
ENCLOSURE		☐ DRIP PROOF		POLES		4 POLES					
		✓ TOTALLY ENCLOSED		ROTOR TYPE			SQUIRREL CAGE				
		☐ Increased Safety Expproof					D	.O.L	Y-		
PROTECTION		IP 55		STARTING METHOD		☐ REACTOR (%TAP) ☑ V.V.V.F				V.V.V.F	
METHODS OF COOLING		☐ SC ☑ FC ☐ AO				☐ SOFT-STARTER					
FREQUENCY		60 Hz		RATED VOLTAGE			440	V		V	V
PHASE		3 PHASE		CURRENT							
SERVICE FACTOR		1.0		NO LOAD				Α		Α	А
INSULATION CLASS		F CLASS		FULL LOAD			9.9	Α		Α	А
TEMP. RISE AT FULL LOAD (at S		S.F 1.0)		STARTING			64.4	Α		Α	А
RES. METHOD		105		EFFICIENCY							
THERMO. METHOD				AT 1/2 LOAD			%				
LOCATION		✓ INDOOR □ OUTDOOR		AT 3/4 LOAD			%				
ALTITUDE		1000 m		AT FULL LOAD			87.0 %				
HUMIDITY		80 %		POWER FACTOR							
AMBIENT TEMPERATURE		-10~40		AT 1/2 LOAD						%	
RATING		✓ CONT.		AT 3/4 LOAD			%				
NEMA DESIGN		В		AT FULL LOAD			84.0 %				
MOUNTING				SPEED (AT FULL LOAD)			1730 rpm				
BEARING	TYPE	BALL		TORQUE							
	DE\N-DE	6	5208ZZ/6206ZZ	FULL L				3.10	kg-r		100%
	LUBRICANT		GREASE		D ROTOR			4.95	kg-r		160%
COUPLING METHOD		✓ DIRECT		BREAKDOWN					kg-r		200%
SHAFT				NOISE LEVEL			74.0			dB(A)	
EXTENSION		SINGLE		VIBRATION			15.0 μ m				
EXTERNAL THRUST				ALLOWABLE LOAD GD ² REFERREI) TO MOTOR SHAFT				
TERMINAL BOX		T		(AT DIRECT ON-LINE)				22.2		kg-m ²	
MAIN		STEEL AL CAST		Motor GD ²			0.1030			kg-m ²	
AUX.		☐ YES ☑ NO		MOTOR APPROX. WEIGHT			58.0			kg	
BOX LOC			LEFT	PAINTING	MUNSELI	L NO.		7.	.1 B 4.0	0/0.9	
APPLICATION STANDARDS		IEC, KS			THICKNESS			✓ STANDARD			μ m
ACCESSORIES (OPTIONAL)				SUBMITTAL DRAWINGS							
NOTE				DE:::-	21/0						
NOTE 1 THESE DATA	REMARKS 1. ABOVE ALL DATA ARE CALCULATED AT 100% VOLTAGE.										
1. THESE DATA GUARANTEEI	I. ABUVE A	LL DATA AR	E CALCULA	ATED A	1 100%	VULTAG	⊏.				
2. OTHERS NOT											
	NCE WITH OTIS STA										
FC : FAN COO	LED	SC : SELF COOLED		DATE F		PREPA	PARED CHECK		CKED	APPROVED	
AO : AIR OVER				2008.	06.05	S.M.Ł		J.H	H.JO	Н	.J.KIM